


Angle for protection of wall panels during transport only
L 60x6x6 to remove before connection to side wall column.
The Channel grinded in the range of weld seams and repair the paint damage.



1	01	Released for Erection	25.01.2019
Rev. no.	Revision	Revision description	Revision date

PROJECT
ESP - PTOLEMAIS V
SUBJECT: GA AXIS 10,16 - LEFT FILTER
SIDE WALLS (1/2)

FABRICATOR:
EMEK

Phases:
28

EMEK
ΕΜΗΝΙΚΕΣ ΜΕΤΑΛΛΙΚΕΣ ΚΑΤΑΣΚΕΥΕΣ
SEBIM SPA, ATIPPOPIPOZ, Tm, 2105555034, Fax 2105555037
ΑΡΧΙΤΕΚΤΟΝΙΚΟ ΑΤΜΗ ΟΡΓΕΙΟ, Τηλ. 2102552024, Fax 2102552045

Project:
1811 - 0.0.05160.00
Drawing: G [32]
Size: A0
PROJECTION

Fabrication and erection acc. to
NEN-EN 1090-2:2008+A1:2011
Execution class: EXC2
Effective tolerance class: 1

Project:
1811 - 0.0.05160.00
Drawing: G [32]
Size: A0
PROJECTION