



NOTES:

- Execution class EXC2 to IS EN 1090
- CE service category sc1
- All structural steel to be grade S355J2
- All bolts to comply with en-iso 4017 standard (fully threaded), grade 8.8 U.N.O.
- All bolts, screws and nuts to be sheradized in accordance with BS9421
- Structure to be painted. For painting spec. refer to Downs Associates Structural Steel Specification - 002.06
- All welds to be continuous 6mm fillet u.n.o.

Distance of threaded bar to the concrete edge is only 40mm (recommended ~100mm).
Currently depth of RC beams in grid 14 is 450mm. Are they already done?
If no, can they depth be increased to 550mm?